

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR22110 Discharge Number: 001A

Facility: CAVE CITY SEWER

Address: PO BOX 69

City: CAVE CITY State: AR Zip: 72521

Contact: Jim Smith Phone: 870-283-2789

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>7-15-2020</u>	<u>DO</u>		<u>5.45</u>	<u>6.0 min</u>

We feel this problem was due to: On the Tues before the testing transformer at the plant regulated by APTI malfunctioned leaving the plant without power for a few hours.

We plan on correcting the problem in this manner: The problem was corrected by 8:45 am when I called for problems to be corrected. Plant was up & running

Time estimated that it will take to correct problem: Corrected

Sincerely,

Jim Smith
Authorized Signature

8/24/2020
Date