

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality - Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0022110 Discharge Number: 001-A
Facility: CITY OF CAVE CITY
Address: 200 FOLEY DR
City: CAVE CITY State: AR Zip: 72521
Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
3/9/22	DO INSTANTANEOUS MINIMUM		6.1	7.0

We feel this problem was due to:

Strong winds the night before blew a limb in to the aeration and stopped aeration temporarily fixed problem immediately


We plan on correcting the problem in this manner:

We corrected problem at the time tester arrived

Time estimated that it will take to correct problem:

problem corrected that day

Sincerely,


Submitted By: _____

4/20/22
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

MCR Form 2