

REPORT OF NON COMPLIANCE

NAME OF FACILITY CAVE CITY, CITY OF

PERMIT NUMBER AR0022110 001-A

PERIOD ENDING December 2013

PARAMETER VIOLATED

REPORTED VIOLATIONS

PARAMETER VIOLATED

DO CONC MO AVG MIN							
6.5							
8.0							

WEEK OF Dec 23 13

Please fill out the following information

CAUSE OF VIOLATION

Breaker to Areatas had been thrown sometime in the night and when I checked it on the day of sampling I kicked it back on.

DURATION OF VIOLATION

No more than 12 hrs.

CORRECTIVE ACTION

turned breaker back on.

EXPECTED COMPLIANCE DATE

the same day

Jim Smith 1/21/14
SIGNATURE / DATE