



310 Maple Avenue • Box 247
Phone: (479) 752-3912

May 14, 2021

Gavin Grey
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Mr. Gavin Grey,

The month of April 2021 we had one violation of our Nitrate permit limit. On April 13th we had a lab result of 13.2 mg/l. We attribute this to a decreased amount of BOD we are receiving in the influent wastewater stream. We have made adjustments to the on and off air cycling to fix this. Since then, our Nitrates have run higher each day but in compliance.

If necessary, we will look into carbon addition. But for the time being we believe on and off air cycling control will remedy the problem.

If you have any questions or concerns, please give me a call at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur