

ADEQ

ARKANSAS
Department of Environmental Quality

June 15, 2012

Mr. James Boston
City of Decatur
P.O. Box 247
Decatur, AR 72722

RE: NPDES Permit Number AR0022292, AFIN 04-00052
NPDES Permit Effluent Violation

Dear Mr. Boston:

A review of the DMRs for the April 2012 monitoring period revealed that your facility violated the following permit effluent limitation:

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT
001B	Total Nitrite plus Nitrate (INST MAX, mg/L)	13.7	10

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0632 or e-mail at bolenbaugh@adeq.state.ar.us.

Thank you,



Jason R. Bolenbaugh
Enforcement Analyst
Water Division Enforcement Branch