

January 21, 2020

Hon. Robert Tharp, Mayor
City of Decatur
P.O. Box 247
Decatur, AR 72722

RE: NPDES Permit Number AR0022292, AFIN 04-00052
Permitted Effluent Limitation Violations

Dear Mayor Tharp,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 1 violation of Part I, Section A of NPDES Permit No. AR0022292 during the review period. A detailed list of the violation has been included with this letter. The Department expects the City of Decatur to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

The Department recommends that the City of Decatur consult with a professional engineer for the purpose of developing a corrective action plan (CAP) designed to eliminate violations of the effluent limitations of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit requires that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at gavin.gray@adeq.state.ar.us.

Sincerely,



Gavin Gray
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
11/30/2019	001-B1	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	6.2	12.3	98%