

September 6, 2018

Hon. Robert Tharp, Mayor City of Decatur P.O. Box 247 Decatur, AR 72722

RE: NPDES Permit Number AR0022292, AFIN 04-00052 Permitted Effluent Limitation Violations

Dear Mayor. Tharp,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility for the reveals the following compliance issues:

The facility has reported 6 violations of Part I, Section A of NPDES Permit No. AR0022292 during the review period. A detailed list of the violations has been included with this letter. The Department expects the City of Decatur to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at gavin.gray@adeq.state.ar.us.

Sincerely,

GaniGizz

Gavin Gray Enforcement Analyst Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
07/31/2018	001-B	Nitrogen, ammonia total [as N], MO AVG, lb/d	29.4	325.16	1, 00 6%
07/31/2018	001-B	Nitrogen, ammonia total [as N], MO AVG, mg/L	1.6	17.13	971%
07/31/2018	001-B	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	3.9	35.4	808%
07/31/2018	001-B	Phosphorus, total [as P], 7 DA AVG, mg/L	1	1.05	5%
07/31/2018	001-B	Coliform, fecal general, 30DA GEO, #/100mL	200	722.65	261%
07/31/2018	001-B	Coliform, fecal general, 7 DA GEO, #/100mL	400	4573.2	1,043%