



310 Maple Avenue • Box 247
Phone: (479) 752-3912

February 20, 2019

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP in January 2019 exceeded the following permit limits, seven day average Ammonia 6.17 mg/l, thirty average 14.76 mg/l, and pounds per day of Ammonia 139.4 lbs. One day of high Nitrates 10.7 mg/l.

During the month of January we had some exceptionally high flow days, our highest being 3.11 MGD. We did make improvements to our discharge limits during the month as parts of our Wastewater plant expansion came on line.

Our contractor is will into construction to expand our Wastewater treatment plant. Our new U.V. disinfections unit is online and we are seeing great results since November. Until we are completed we will continue to do our very best to meet all of our permit limits.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur