



310 Maple Avenue • Box 247
Phone: (479) 752-3912

April 23, 2018

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP in March 2018 exceeded the following permit limits, seven day average Ammonia, TSS, and Fecal Coliform, thirty average, and pounds per day of, TSS, Ammonia, and Fecal Coliform.

Again for the month of March especially the first and last week of the month, problems were mainly caused by several high flow days due to rainfall, and lack of treatment time. We had a few days where effluent discharge exceeded 3 MGD, one day exceeded 3.5 MGD. This is not enough time to nitrify.

Our contract has begun construction to expand our Wastewater treatment plant. We have an expected completion date of late November 2018. Until then we will continue to do our very best to meet all of our permit limits. Sewer line lining is set to begin the second week of May to help us with our I&I problems.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur