



310 Maple Avenue • Box 247  
Phone: (479) 752-3912

May 24, 2017

Michelle Bolenbaugh  
Enforcement Analyst  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP exceeded our Ammonia 30 average limit, and had two 7 day average exceedances, along with the pounds per day exceedance. We also exceeded our fecal coliform 7 day average 1 time.

The month of April into May have been summed up by several rainfall events that has caused us flows that have exceeded our plants ability. We are moving ahead with our upgrade plans, and they are at the ADH and ADEQ for review. Until then we will continue to do our very best to meet all of our permit limits.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston  
Public Works Manager  
City of Decatur