



310 Maple Avenue • Box 247  
Phone: (479) 752-3912

September 19, 2017

Michelle Bolenbaugh  
Enforcement Analyst  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP exceeded our Ammonia 30 average limit, and had five 7 day average exceedances. We also exceeded our fecal coliform seven day average 1 time. Also we exceeded our TSS 30 day average, pounds per day and our seven day average 1 time.

Our plant is facing very high flows during the week. We did replace our UV bulbs and we have seen good results in August. We are moving ahead with our upgrade plans. The plans have been submitted to your department for review. Until then we will continue to do our very best to meet all of our permit limits.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston  
Public Works Manager  
City of Decatur