



310 Maple Avenue • Box 247
Phone: (479) 752-3912

January 25, 2017

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP had one permit limit exceedance on our 7 day average for Total Suspended Solids. This happened on week four of the month.

We believe we had a person or persons turn an outside equipment switch during the night that caused us to have issues the next day. We thought that the solids number would average out but it did not. We have purchased security cameras and are in the process of getting them installed to catch future problems.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur