



310 Maple Avenue • Box 247
Phone: (479) 752-3912

March 23, 2020

Gavin Grey
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Mr. Gavin Grey,

The Decatur WWTP on February 4, 2020 exceeded the following permit limit, one instantaneous limit on Nitrate, we had a 10.9 mg/l result according the Certified Lab results.

This is the number we must report. We do not believe we were that high on February 4th, our inhouse process control numbers showed our Nitrates on that day being more in the 5-7 mg/l range.

We will continue to strive to keep our limits in compliance with our permit.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur