



310 Maple Avenue • Box 247
Phone: (479) 752-3912

February 25, 2017

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP exceeded our Ammonia 30 average limit, and had two 7 day average exceedances. We also exceeded our fecal coliform 30 day and seven day average 2 times.

Our wastewater plant has had days of high flows that have shown up with these two permit limits in particular. We are moving ahead with our upgrade plans and hope to have them for your review as early as March. Until then we will continue to do our very best to meet all of our permit limits.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

A handwritten signature in dark ink, appearing to read "James Boston". The signature is written in a cursive style with a large initial "J".

James Boston
Public Works Manager
City of Decatur