



310 Maple Avenue • Box 247
Phone: (479) 752-3912

July 20, 2017

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP exceeded our Ammonia 30 average limit, and had four 7 day average exceedances. We also exceeded our fecal coliform 30 day and seven day average 5 times.

Our plant is facing very high flows during the week. We are going to replace our UV bulbs this weekend to see if we can get the Fecal Coliform numbers down and hopefully in compliance. We are changing bulbs earlier than normal. We are moving ahead with our upgrade plans. The plans have been submitted to your department for review. Until then we will continue to do our very best to meet all of our permit limits.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

A handwritten signature in dark ink, appearing to read "James Boston". The signature is written in a cursive style with a large initial "J".

James Boston
Public Works Manager
City of Decatur