



310 Maple Avenue • Box 247

Phone: (479) 752-3912

April 21, 2022

Leslie Allen-Daniel
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Daniel,

The Decatur WWTP exceeded our 7-day average ammonia permit limit for Ammonia 1 week in March 2022. The average for the week was 6.3 mg/l, our permit limit is 6.2 mg/l.

The reason for our problems with Ammonia that week was caused by a motor that went bad on one of our aeration blowers. We did have a spare, but it takes several hours to install the motor. During that time ammonia rose in that basin and was difficult to bring down for a couple of days.

If you have any questions or concerns, please give me a call at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur