



310 Maple Avenue • Box 247

Phone: (479) 752-3912

October 23, 2016

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP had permit limit exceedance on our 7 day average, pounds per day and the 30 day average for Ammonia. Also during the month of September we had exceedance of our Fecal Coliform 30 day average and our 7 day average.

Due to our hydraulic loading and treatment time under aeration we are having difficulty with our strict limit on ammonia. We are using supplemental oxygen to help. Our Fecal Coliform issues could have been caught sooner with quicker notification from our contract lab. We have since resolved those issues and as of the middle of October the problems with UV have been resolved. We are teamed up with a design build team to help us with our plant expansion. We will continue to strive to have complete compliance.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur

Decatur Water & Waste Water

P.O. Box 247 • 310 Maple Ave.

Decatur, Arkansas 72722

NORTHWEST AR PSDF

25 OCT 2016



PITNEY BOWES

\$ 000.67⁵

02 1P

0001682146 OCT 25 2016

MAILED FROM ZIP CODE 72722

Arkansas Dept of Environmental Quality
Water Division - Enforcement Branch
5301 Northshore Drive
North Little Rock AR 72118-5317

7211885317

