



310 Maple Avenue • Box 247
Phone: (479) 752-3912

December 21, 2018

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP in November 2018 exceeded the following permit limits, seven day average Ammonia, thirty average, and pounds per day of Ammonia. We also exceeded our TSS 30 day and seven day average limit, and pounds per day.

We do continue to struggle with the above permit limits due to high influent plant flow. Our fecal coliform numbers fell into place the Month of November, with no violations. The month of December our TSS and numbers have shown drastic improvements.

Our contractor is well into construction to expand our Wastewater Treatment Plant. We have an expected possible completion date the end of January 2019. Until then we will continue to do our very best to meet all of our permit limits.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur