



310 Maple Avenue • Box 247
Phone: (479) 752-3912

November 17, 2016

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP had two permit limit exceedance on our 7 day average for Fecal Coliform. This happened the first two week of the month.

We have since resolved the Fecal Coliform issues, and as of the middle of October the problems with the UV have been resolved by an outside company U.V. Doctor.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

A handwritten signature in dark ink, appearing to read "James Boston". The signature is written in a cursive, flowing style.

James Boston
Public Works Manager
City of Decatur