

Record of Communication

Key#: 759 **Date:** 7/30/2015 3:12: **Facility:** City of Decatur

From: Kyle Barber, ADEQ Water Enforcemen **NPDES #:** AR0022292

To: James Boston, Public Works Mgr.

I spoke with Mr. James Boston of the City of Decatur about the eight (8) total suspended solids (TSS) violations and two (2) phosphorus violations the facility has reported from the monitoring periods ending 03/31/2015 through 05/30/2015. The city is currently working on a facility upgrade, for which they received approval and a construction permit from ADEQ. Mr. Boston confirmed that the plant upgrades will address the TSS and phosphorus issues, and he estimated that the facility is sixty (60) days from final compliance.