

Record of Communication

Key#: 737 **Date:** 5/27/2015 **Facility:** City of Decatur
From: 8:40 **NPDES #:** AR0022292
To: 8:43

The city reported two overflows in that location on 5/25. I spoke with the Public Works Manager, James Boston, and he said that the overflow started and stopped twice, hence the two reports. He said that at the current time the overflow has stopped, and the city's plan is to fix the problem upstream as soon as the weather is dry for a sufficient length of time. They suspect that the problem is a line separation.