

310 Maple Avenue • P.O. Box 247

Phone: (479) 752-3912

January 25, 2014

Mr. Mo Shafii  
Water Division ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NCR report December 2013 TSS Limit

Dear Mr. Shafii,

During the week of December 2013 the Decatur WWTP had a bad day trying to keep our Total Suspended Solids in compliance. The extreme cold has caused valve freezing that has lead to lost air and treatment times. This problem has carried over into January as well and I will tell more about the improvements we are in the process of making, to make sure these same problems do not happen again.

We have had our new WWTP in service since 2009 and have been very good at meeting our permit limits. We will solve the problems that we did not know we had before this cold snap.

If you have any questions or concerns please contact me at 479-752-3912.

Sincerely,


A handwritten signature in cursive script that reads "James Boston".

James Boston  
Public Works Manager  
City of Decatur



**Decatur Water & Waste Water**

P.O. Box 247 • 310 Maple Ave.  
Decatur, Arkansas 72722



02 1P \$ 000.66<sup>0</sup>  
0001682146 JAN 25 2014  
MAILED FROM ZIP CODE 72722

Arkansas Dept. of Environmental Quality  
Water Division-Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

7211885317

