



310 Maple Avenue • P.O. Box 247

Phone: 479.752.3912

March 24, 2014

Mr. Mo Sháfii
Water Division ADEQ
5301 Northshore Drive
North Little Rock, AR 72118.

RE: NCR report February 2014 Nitrate Limit

Dear Mr. Shafii,

During the first week of February 2014 the Decatur WWTP had problems with our Nitrate limit compliance on two days. This problem was a carry over from the January problems we had with freezing valves and other problems caused by the extreme cold weather. We have dealt with the valve freezing problems and we have not had anymore nitrate issues since the first week of February.

We are doing our best to insure we do not have the kind of cold weather issues we had this year again.

If you have any questions or concerns please contact me at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur

Sanitary Sewer Overflow Monthly Report

Facility Name: DECATUR, City of

Permit Number: 22292

Reporting Period (Month/Year): 02/2014

No Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO		Summary Report Code Descriptions		
		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order	CR-Creek/Stream/River (please specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure/Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots & Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location

Jim A. B... Public Works Manager
 Signature of Cognizant or Ranking Official

3/24/2014
 Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Decatur Water & Waste Water

P.O. Box 247 • 310 Maple Ave.

Decatur, Arkansas 72722



02 1P **\$ 000.69⁰**
0001682146 MAR 24 2014
MAILED FROM ZIP CODE 72722

Arkansas Dept. of Environmental Quality
Water Division-Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118-5317

721185317 R015

