



310 Maple Avenue • P.O. Box 247

Phone: 479.752.3912

May 23, 2014

Mr. Mo Shafii
Water Division ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: NCR report April 2014 Nitrate Limit

Dear Mr. Shafii,


During the second and third week of April 2014 the Decatur WWTP had compliance issues with our Nitrate limit one day of each week. One of our SBR tanks has been having a hard time recuperating from the January extreme cold temperatures. We did have one day in May that was an issue but over the past couple of weeks our efforts getting it turned around appear to be paying off.

We are striving to keep our Nitrates from jumping around on us; we did have a 7.16 mg/l average for the month.

If you have any questions or concerns please contact me at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur



310 Maple Avenue • Box 247
Phone: 479.752.3912

NORTHWEST AR P&DF

23 MAY 2014



02 1P \$ 000.69
0001682146 MAY 23 2014
MAILED FROM ZIP CODE 72722

Arkansas Dept. of Environmental Quality
Water Division - Enforcement Branch
5301 North Shore Drive
North Little Rock, AR 72118-5317

72118\$5317

