



310 Maple Avenue • P.O. Box 247

Phone: 479.752.3912

June 23, 2014

Mr. Mo Shafii  
Water Division ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NCR report April 2014 Nitrate Limit

Dear Mr. Shafii,

During the first week of May 2014 the Decatur WWTP had a compliance issue with our Nitrate limit one day of week; the number was 11.2 mg/l. Since the first week of May we have been doing great and back to some normality since the problems in January with the freezing valve situation that has kept us in catch up mode ever since. We feel like we are in great shape for the foreseeable future, this is a very hard limit for us to meet.

We are striving to keep our Nitrates in compliance; we did have a 7.34 mg/l average for the month.

If you have any questions or concerns please contact me at 479-752-3912.

Sincerely,

James Boston  
Public Works Manager  
City of Decatur



**Decatur Water & Waste Water**

P.O. Box 247 • 310 Maple Ave.  
Decatur, Arkansas 72722



02 1P **\$ 000.69<sup>0</sup>**  
0001682146 JUN 24 2014  
MAILED FROM ZIP CODE 72722

Arkansas Dept. of Environmental Quality  
Water Division-Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

721185317 0015

