



310 Maple Avenue • P.O. Box 247

Phone: 479.752.3912

May 25, 2016

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP had permit limit exceedance on our 7 day average, pounds per day and the 30 day average for Ammonia.

Due to our mainly our hydraulic loading and treatment time under aeration we are having difficulty with our strict limit on ammonia. To combat this problem we feel we can improve the amount of aeration to the plant by supplementing our oxygen supply through the partnership with a supplemental oxygen system company. We hope to be up and running with this system by the end of June 2016. Only a plant expansion will help us with the treatment time. We are teamed up with a design build team to help us with our plant expansion.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

A handwritten signature in black ink, appearing to read "James Boston".

James Boston
Public Works Manager
City of Decatur

Decatur Water & Waste Water

P.O. Box 247 • 310 Maple Ave.

Decatur, AR 72722

NORTHWEST AR P&DF

25 MAY 2016



02 1P
0001682146 MAY 04 2016
MAILED FROM ZIP CODE 72722

Arkansas Dept of Environmental Quality
Water Division - Enforcement Branch
5301 Northshore Drive
North Little Rock AR 72118-5317

7211835317

