

310 Maple Avenue • P.O. Box 247

Phone: 479.752.3912

January 24, 2015

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP had permit limit problems concerning the 7 day average portion of our permit for TSS. This problem occurred on the fourth week of the month in December.

A very cold, wet, and cloudy December did not help the biology of the WWTP at all. Our disk filter catches most of the solids but what it has not caused our violation, and a close call on our phosphorus 7 day average as well.

We will be submitting plans to your department and the ADH that should insure great results in staying within our permit limits for the foreseeable future. We hope to have this new equipment on line by the end of May. In the mean time we will continue to do our best to control the solids issues with what we have in place.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur


Decatur Water & Waste Water

P.O. Box 247 • 310 Maple Ave.
Decatur, Arkansas 72722

NORTHWEST AR P&DE

AR 72722

26 JAN 2015



02 1P

\$ 000.69⁰

0001682146 JAN 24 2015

MAILED FROM ZIP CODE 72722

Arkansas Dept. of Environmental Quality
Water Division-Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118-5317

7211835317

