

310 Maple Avenue • P.O. Box 247

Phone: 479.752.3912

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP had permit limit problems concerning the 7 day and the 30 day average of our permit for Ammonia. Also during the month of December we had two weeks that our Fecal, Ammonia, and TSS numbers were high. These numbers were directly related to the approximately 24 inches of rainfall we had during the month. The second and last week of the month were particularly hard on our WWTP.

During these rainfall events we learned of different I&I points that are causing us problems. We found an area that we believe was causing us the majority of our bad I&I. I sought and got approval to have 19 manholes rehabbed during the month of January 2016 and we believe that it will make a huge difference during our next rainfall event.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur

Decatur Water & Waste Water


P.O. Box 247 • 310 Maple Ave.

Decatur, Arkansas 72722

NORTHWEST AR 72722

AR 72722

26 JAN 2016



02 1P

\$ 000.70⁵

0001682146 JAN 25 2016

MAILED FROM ZIP CODE 72722

Arkansas Dept of Environmental Quality
Water Division-Enforcement Branch
5301 Northshore Drive
N. Little Rock AR 72118-5317

72118+5317

