



310 Maple Avenue • P.O. Box 247

Phone: 479.752.3912

March 21, 2016

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: NCR report February 2016

Dear Ms. Bolenbaugh,

During the second week of February 2016 the Decatur WWTP had compliance issue with our Fecal Coliform limit two days of that week. We have traced this to our UV system not putting out enough transmittance to do an effective treatment. We have since replaced the UV bulbs and are watching the results closely. Unfortunately these results are not know for a week or two later but we are going to work closely with our lab to get these results next day or in two days until we are convinced the problem is fixed.

Also during the month we had problems meeting our Ammonia 30 day average. This seems to be trending down but high flows make it a challenge. We are currently working with an engineering company to help us with our capacity issues and expect to have a plan for you to review very soon.

If you have any questions or concerns please contact me at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur

Decatur Water & Waste Water

P.O. Box 247 • 310 Maple Ave.

Decatur, Arkansas 72722

NORTHWEST AR PSD/F

AR 72722

22 MAR 2016



02 1P

\$ 000.70⁵

0001682146 MAR 21 2016

MAILED FROM ZIP CODE 72722

Arkansas Dept of Environmental Quality
Water Division-Enforcement Branch
5301 Northshore Drive
North Little Rock AR 72118-5317

72118+5317

