



310 Maple Avenue • P.O. Box 247

Phone: 479.752.3912

Michelle Bolenbaugh  
Enforcement Analyst  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP had one permit limit exceedance on our 7 day average, and the 30 day average of our permit for Ammonia.

A lot of the January problems with Ammonia was due to catching up from the unusual rainfall amounts we had in December, and particularly the end of the month in December. We are going to be seeing higher flows until our expansion is done. In the meantime we are working seven days a week to try and keep our plant within our permit limits.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston  
Public Works Manager  
City of Decatur

**Decatur Water & Waste Water**

P.O. Box 247 • 310 Maple Ave.

Decatur, AR 72722

NORTHWEST AR PS/DIF

AR

19 FEB 2016



PITNEY BOWES

\$ 000.705

02 1P

0001682146 FEB 19 2016

MAILED FROM ZIP CODE 72722

Arkansas Dept. of Environmental Quality  
Water Division - Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

72118+5317

