

310 Maple Avenue • P.O. Box 247

Phone: 479.752.3912

July 24, 2015

Michelle Bolenbaugh  
Enforcement Analyst  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP had permit limit problems concerning the 7 day and the 30 day average of our permit for TSS. Also during the month of June we had on week that our phosphorus permit 7 day average was 1.17 mg/l average for the week.

Another very wet month did not help our efforts to stay in our compliance range. We have received approval from your Department to begin the process of adding an Act-flo treatment system that will target TSS and Phosphorus.

In the mean time we will continue to do our best to control the solids and phosphorus issues with what we have in place. And hope for a little dryer weather.


If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston  
Public Works Manager  
City of Decatur

**Decatur Water & Waste Water**  
P.O. Box 247 • 310-Maple-Ave.  
Decatur, Arkansas 72722

NORTHWEST AR POST  
AR 72722  
27 JUL 2015 1:54 PM



Arkansas Dept. of Environmental Quality  
Water Division-Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118-5317

72118+5317

