



310 Maple Avenue • P.O. Box 247

Phone: 479.752.3912

April 20, 2016

Michelle Bolenbaugh  
Enforcement Analyst  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP had one permit limit exceedance on our 7 day average, and the 30 day average of our permit for Fecal Coliform.

Our UV unit has worked great for several years. We recently noticed the numbers climbing a little on the fecal counts. We did a deep cleaning, changed bulbs and sleeves again to no avail. After back and forth with the manufacture of the unit we seem to have it working normal again. We have requested a factory representative to visit our site as soon as they are available to do so to make sure all problems are fixed. So far the month of April our fecal coliform counts have been very low.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston  
Public Works Manager  
City of Decatur

**Decatur Water & Waste Water**

P.O. Box 247 • 310 Maple Ave.

Decatur, Arkansas 72722

NORTHWEST AR. P&DF

AR

22 APR 2016



02 1P  
0001682146 APR 22 2016  
MAILED FROM ZIP CODE 72722

**\$ 000.675**

Arkansas Dept. of Environmental Quality  
Water Division - Enforcement Branch  
5301 Northshore Drive  
North Little Rock AR 72118-5317

7211895317

