



310 Maple Avenue • P.O. Box 247

Phone: 479.752.3912

June 25, 2015

Michelle Bolenbaugh
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Ms. Bolenbaugh,

The Decatur WWTP had permit limit problems concerning the 7 day and the 30 day average of our permit for TSS.

Rain and drastic changing of temperatures has caused us settling issues leading to the high TSS numbers. We feel like the plans we have submitted to your Department that we have received preliminary approval for will rectify the solids and higher phosphorus issues. We have received ADH approval last month on the plant upgrades.

In the mean time we will continue to do our best to control the solids and phosphorus issues with what we have in place.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston
Public Works Manager
City of Decatur

Decatur Water & Waste Water

P.O. Box 247 • 310 Maple Ave.

Decatur, Arkansas 72722

NORTHWEST AR PSD F

AR

JUN 25 2015



02 1P
0001682146 JUN 25 2015
MAILED FROM ZIP CODE 72722

\$ 000.705

Arkansas Dept. of Environmental Quality
Water Division-Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118-5317

72118+5317

