



310 Maple Avenue • Box 247
Phone: (479) 752-3912

March 11, 2021

Gavin Gray
Enforcement Analyst
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

RE: Decatur Permit Violations Permit Number AR0022292, AFIN 04-00052

Dear Mr. Gavin Grey,

The month of February 2021 has been a tough month for the Decatur Wastewater Treatment Plant. Starting with an electrical storm on the early hours of January 31st to the week of February 14th and the extreme cold weather. We did not have any numbers to report during the week of February 14th due to the plant being down because of the extreme cold, most of this water we would have treated was stored in or retention pond. I will address the DMR issues in this NCR response.

We were only able to get 8 of our 12 sample days done. The days of no testing were due to not being able to get samples pulled due to no flow, and our testing lab being unreachable because of road conditions. Every attempt was made to get testing done. And we were able to test every week at least once except the week of the 14th. With all that said we did remain in compliance with our permit for all tested parameters.

If you have any questions or concerns please give me a call at 479-752-3912.

Sincerely,

James Boston
Public Works Manager

