

Environmental Services Company, Inc.

Corporate Office
 13715 West Markham
 Little Rock, AR 72211
 Tel. (501)221-2565 Fax (501)221-1341

Northwest Arkansas Branch
 1107 Century Avenue
 Springdale, AR 72762
 Tel. (479)750-1170 Fax (479)750-1172

Control Number: 1512010331

Customer Name : CAMDEN WATER & WASTEWATER UTILITY

Customer Number : 1550

Report Date : 12/21/15

Composite Date:12/15/16 -12/15/16

Sample Time : 1000-1500

Sample Type : COMPOSITE WASTEWATER

Sample From : FINAL EFFLUENT

Collected By: AS

Delivery By : TMO

Work Order :

Purchase Order :


Laboratory Analysis

Analysis						Quality Assurance		
Date	Time By	Parameter	Result	Notes	Quantity	Method	Precision	Accuracy
							% RPD	% Recovery
12/18	1700 NTR	Phosphorous, Total (as P)	< 0.05 mg/L			EPA 365.3	0.00	94.2 *
12/18	1510 NTR	Nitrate + Nitrite	2.87 mg/L			SM 2000 4500-NO3 E	1.84	98.7 *

* QA data shown is from a different sample or standard on the same date.

All equipment used is checked and/or calibrated daily. All NPDES testing is conducted in accordance with 40 CFR Part 136. A minimum of 10% spiked and duplicate samples is run on each parameter where applicable for Quality Assurance purposes. Quality Assurance Plan on file with Arkansas Department of Environmental Quality. Analysis time indicates the time of the start of the analytical batch in which the specific sample was included.

Signature _____


 Environmental Services Co., Inc.




Camden
Water
Utilities

P.O. BOX J
CAMDEN, AR 71711

LITTLE ROCK AR 722

13 JAN 2016 PM 4 L



ADEQ

Water Division-Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118-5317

72118531799

