Sanitary Sewer Overflow Monthly Report

Facility Name: CAMDEN WATER UTILITIES **Permit Number:** AR0022365 **Reporting Period(Month/Year):** 07/2015

☐ No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions

Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order	CR-Creek/Stream/River (please specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure/Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots & Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location
California + Chestnut		07/30/2015	07/30/2015	100	D	NEAH	HC	GR

Thomas K Bellard
Signature of Cognizant or Ranking Official

08/13/2015
Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Environmental Services Company, Inc.

Corporate Office
13715 West Markham
Little Rock, AR 72211
Tel. (501)221-2565 Fax (501)221-1341

Northwest Arkansas Branch
1107 Century Avenue
Springdale, AR 72762
Tel. (479)750-1170 Fax (479)750-1172

Control Number: 1507010223
Customer Name : CAMDEN WATER & WASTEWATER UTILTY
Customer Number : 1550
Report Date : 07/21/15

Composite Date:07/14/15 -07/14/15
Sample Time : 1000-1500
Sample Type : COMPOSITE WATER
Sample From : FINAL EFFLUENT

Collected By: ANNETTE STRICKL
Delivery By : TMO
Work Order :
Purchase Order :

Laboratory Analysis

Analysis Date	Time	By	Parameter	Result	Notes	Quantity	Method	Quality Assurance Precision % RPD	Accuracy % Recovery
07/16	1530	ATL	Phosphorous, Total (as P)	< 0.05 mg/L			EPA 365.3	0.00	102.7 *
07/18	0845	NTR	Nitrate + Nitrite	1.61 mg/L			SM 2000 4500-NO3 E	1.58	101.9 *

* QA data shown is from a different sample or standard on the same date.

All equipment used is checked and/or calibrated daily. All NPDES testing is conducted in accordance with 40 CFR Part 136. A minimum of 10% spiked and duplicate samples is run on each parameter where applicable for Quality Assurance purposes. Quality Assurance Plan on file with Arkansas Department of Environmental Quality. Analysis time indicates the time of the start of the analytical batch in which the specific sample was included.

Signature Ned Rye
Environmental Services Co., Inc.