

Environmental Services Company, Inc.

Corporate Office
 13715 West Markham
 Little Rock, AR 72211
 Tel. (501)221-2565 Fax (501)221-1341

Northwest Arkansas Branch
 1107 Century Avenue
 Springdale, AR 72762
 Tel. (479)750-1170 Fax (479)750-1172

Control Number: 1310010355
 Customer Name : CAMDEN WATER & WASTEWATER UTILTY
 Customer Number : 1550
 Report Date : 10/23/13

Composite Date:10/16/13 -10/16/13
 Sample Time : 1003
 Sample Type : COMPOSITE WATER
 Sample From : EFFLUENT

Collected By: ANNETTE STRICKL
 Delivery By : TMO
 Work Order :
 Purchase Order :

<u>Laboratory Analysis</u>						<u>Quality Assurance</u>		
<u>Analysis</u>			<u>Result</u>	<u>Notes</u>	<u>Quantity</u>	<u>Method</u>	<u>Precision</u>	<u>Accuracy</u>
<u>Date</u>	<u>Time</u>	<u>By</u>	<u>Parameter</u>				<u>% RPD</u>	<u>% Recovery</u>
10/18	1015	NTR	Phosphorous, Total (as P)	0.11 mg/L		EPA 365.3	0.56	100.6 *
10/21	0700	NTR	Nitrate + Nitrite	0.31 mg/L		2000 4500-NO3 E	0.98	92.4

* QA data shown is from a different sample or standard on the same date.

All equipment used is checked and/or calibrated daily. All NPDES testing is conducted in accordance with 40 CFR Part 136. A minimum of 10% spiked and duplicate samples is run on each parameter where applicable for Quality Assurance purposes. Quality Assurance Plan on file with Arkansas Department of Environmental Quality. Analysis time indicates the time of the start of the analytical batch in which the specific sample was included.

Signature _____


 Environmental Services Co., Inc.




Camden
Water
Utilities

LOCK DRAWER J
CAMDEN, AR 71711

LITTLE ROCK AR 722

14 NOV 2013 PM 2 1



A.D.E. Q
NPDES Enforcement Division
5301 Northshore Drive
North Little Rock, AR, 72118

72118532801

