

ADEQ

ARKANSAS
Department of Environmental Quality

March 30, 2016

Kent Latch
General Manager
Heber Springs Water and Sewer Commission
Heber Springs Wastewater Treatment Plant
1108 West Front Street
Heber Springs, AR 72543

RE: NPDES Permit Number AR0022381, AFIN 12-00029
NPDES Permit Effluent Violations

Dear Mr. Latch:


The Department recently performed a file review of the above referenced permit. The review revealed the following effluent violations:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	Violation Code	% Vio	Parameter Code
11/30/2015	002-A	Solids, total suspended, 7 DA AVG, mg/L	30	37.8	E90	26%	00530-1-0

Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit requires you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0630 or e-mail at allen-daniel@adeq.state.ar.us.

Sincerely,



Leslie Allen-Daniel
Enforcement Analyst
Water Division, Enforcement Branch