

# ADEQ

ARKANSAS  
Department of Environmental Quality

March 5, 2012

The Honorable David Duch, Mayor  
City of Hazen  
P.O. Box 564  
Hazen, AR 72064

RE: NPDES Permit AR0022411, AFIN 59-00029  
Inadequate Response to Inspection #063787

Dear Mayor Duch:

The Department has received your response to the January 31, 2012 inspection of your construction site by our District Field Inspector, Lindsey Zweifel. Your response does not satisfy the discrepancies identified during the visit for the following reasons:

1. You did not provide photo documentation verifying the unpermitted discharge pipe was capped and reinforced.
2. You did not provide photo documentation verifying the weirs of the clarifier were cleaned of debris.
3. You did not provide an estimated date of completion for installing alarms and signage on the wastewater pumping stations.

Please submit a response to the above items by **March 19, 2012**. Additionally, Mr. Swaim and/or Mr. Foot must obtain the Class II wastewater operator license by the self-imposed date indicated in your letter. If neither obtains said license then you will be required to immediately hire an operator that does possess said license. Finally, the Department expects the corrective actions that have already been taken will be maintained to ensure consistent compliance with the requirements of the permit.

Thank you for your attention to this matter. Should you have any questions please feel free to contact me at 501-682-0632 or you may e-mail me at [bolenbaugh@adeq.state.ar.us](mailto:bolenbaugh@adeq.state.ar.us).

Sincerely,



Jason Bolenbaugh  
Enforcement Analyst  
Water Division Enforcement Branch