

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411 Discharge Number: A - 001-Monthly

Facility: City of Hazen

Address: 1789 Utility Street

City: Hazen

State: AR

Zip: 72064

Contact: Phillip Foot

Phone: 807-255-4521

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Permit Limits
October 14th, 2019	TSS	16.50 Mo. Avg & 23.0 7 Day Avg.	15.0 Mo. Avg & 22.5 7 Day Avg.

We feel this problem was due to:

✓ We feel that the problem is due to excess rainfall
got 1.5" on 10-7 + 1" on 10-11-19

We plan on correcting the problem in this manner:

In time this will correct the problem with no excess rainfall

Time estimated that it will take to correct the problem/s:

3 days/72 hrs

Sincerely,


Authorized Signature

11-19-19
Date