

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411

Discharge Number: A - 001-Monthly

Facility: City of Hazen

Address: 1789 Utility Street

City: Hazen

State: AR

Zip: 72064

Contact: Phillip Foot

Phone: 807-255-4521

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Permit Limits
April 5th, 2021	Fc	2100 cfu/100mls	2000 cfu/100mls

We feel this problem was due to:

*We had a malfunction with the UV  
BVLs*

We plan on correcting the problem in this manner:

*clean the UV lights*

Time estimated that it will take to correct the problem/s:

*2 Weeks*

Sincerely,



Authorized Signature



Date