

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411

Discharge Number: A - 001-Monthly

Facility: City of Hazen

Address: 1789 Utility Street

City: Hazen

State: AR

Zip: 72064

Contact: Phillip Foot

Phone: 807-255-4521

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Permit Limits
Augst 10th, 2020	TSS	26.0 mg/L Mo. Avg & 46.0 mg/L 7 Day Avg.	15.0 Mo. Avg & 22.5 7 Day Avg

We feel this problem was due to:

This problem was due to our main pump going down & we had to use our back-up pump while we waited on parts. Our back-up pumps to the oxidation pond & we were having to treat that water.


We plan on correcting the problem in this manner:

Our pump HAS been repaired & is up & running normally again & our readings are back to normal again.

Time estimated that it will take to correct the problem/s:

Already fixed & already getting good readings

Sincerely,


Authorized Signature

9-28-20
Date