

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411 Discharge Number: A - 001-Monthly

Facility: City of Hazen

Address: 1789 Utility Street

City: Hazen State: AR Zip: 72064

Contact: Phillip Foot Phone: 807-255-4521

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Permit Limits
August 9th,16th,2021	TSS	21.0 mg/l Mo Avg & 26.0 mg/l 7 day Avg	15.0 mg/l Mo Avg & 26.0 mg/l 7 day
August 9th,16th,2021	NH3	5.8 mg/l Mo Avg	5.0 mg/l Mo Avg

We feel this problem was due to:

We have had 2 aerators go out
The finishing pond has reached its capacity for sludge

We plan on correcting the problem in this manner:

We are in the process of getting a crane to replace the aerators
We are going to rent a pump to pump out the finishing pond

Time estimated that it will take to correct the problem/s:

60 days

Sincerely,



Authorized Signature



Date