

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411 Discharge Number: A - 001-Monthly

Facility: City of Hazen

Address: 1789 Utility Street

City: Hazen State: AR Zip: 72064

Contact: Chad Swaim Phone: 870-830-8198

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
January-22	Fc	1002 cfu/100mls 30 day Geometric	1000 cfu/100mls 30 day Geo limit

We feel this problem was due to:

we have had problems with our UV lights, we have tried to repair them but they go out again so we have gotten bids to have the system replaced.

We plan on correcting the problem in this manner:

we are in the process of getting a whole new UV system installed.

Time estimated that it will take to correct the problem/s:

problem is fixed for now, but a new system is coming

Sincerely,


Authorized Signature

2-24-22
Date