

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411

Discharge Number: A - 001-Monthly

Facility: City of Hazen

Address: 1789 Utility Street

City: Hazen

State: AR

Zip: 72064

Contact: Phillip Foot

Phone: 807-255-4521

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Permit Limits
July 20th, 2020	TSS	22.5 mg/L Mo. Avg & 30.0 mg/L 7 Day Avg.	15.0 Mo. Avg & 22.5 7 Day Avg

We feel this problem was due to:

we had a pump that ^{is} our main pump & it went down & until we could get parts we had to use our back-up pump which pumped into our oxidation pond & we had to treat that water.


We plan on correcting the problem in this manner:

we have gotten all parts & the main pump is running as normal again

Time estimated that it will take to correct the problem/s:

pump is fixed so readings should return to normal

Sincerely,


Authorized Signature

8-25-20
Date