

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411

Discharge Number: A - 001-Monthly

Facility: City of Hazen

Address: 1789 Utility Street

City: Hazen

State: AR

Zip: 72064

Contact: Phillip Foot

Phone: 807-255-4521

| Date of Non-Compliance | Parameter Exceeded | Quantity or Loading | Permit Limits |
|------------------------|--------------------|--|-------------------------------|
| June 1st & 15th, 2020 | TSS | 30.5 mg/L Mo. Avg & 35.0 mg/L 7 Day Avg. | 15.0 Mo. Avg & 22.5 7 Day Avg |
| | | | |
| | | | |

We feel this problem was due to:

we have been wasting first of the week so we feel samples were taken too close to the time we wasted


We plan on correcting the problem in this manner:

we are no longer going to waste on the day they take samples

Time estimated that it will take to correct the problem/s:

should be corrected now that we are aware and can adjust our schedule

Sincerely,


Authorized Signature

7-30-20
Date