

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411

Discharge Number: 001-A-Monthly

Facility: Hazen

Address: 1789 Utility Street

City: Hazen

State: AR

Zip: 72064

Contact: Chad Swaim

Phone:

8708308198

| Date of Non-Compliance | Parameter Exceeded | Quantity or Loading | Quality or Concentration | Permit Limits        |
|------------------------|--------------------|---------------------|--------------------------|----------------------|
| May-23                 | Fecal              |                     | >2420MPN/100mL 7D Geo    | 2000MPN/100mL 7D Geo |
| May-23                 | Fecal              |                     | 1254MPN/100 30D Geo      | 1000MPN/100 30D Geo  |
|                        |                    |                     |                          |                      |
|                        |                    |                     |                          |                      |

We feel this problem was due to:

We have several U.V. lights that are out

We plan on correcting the problem in this manner:

We have the U.V. lights ordered, they are on back order

Time estimated that it will take to correct the problem/s:

1 month

Sincerely,

*Mason Mark*

Authorized Signature

6-23-23

Date