

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411

Discharge Number: 001-A-Monthly

Facility: Hazen

Address: 1789 Utility Street

City: Hazen

State: AR

Zip: 72064

Contact: Chad Swaim

Phone:

8708308198

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
November, 2022	DO		2.24 mg/l Inst Min	5.0 mg/l Inst Min
November, 2022	NH3		22.6 mg/l 7day Avg	13.5 mg/l 7day Avg
November, 2022	Fc		>2400 MPN/100mls	2000 7 Day Geometric

We feel this problem was due to:

We have gotten an excessive amount of rainfall
several days of 1.5"-2" of rainfall, also we have had some UV lights go out

We plan on correcting the problem in this manner:

We have made preparations to get all new UV lighting system

Time estimated that it will take to correct the problem/s:

1 month

Sincerely,



Authorized Signature

12-22-22

Date