

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411 Discharge Number: A - 001-Monthly

Facility: City of Hazen

Address: 1789 Utility Street

City: Hazen State: AR Zip: 72064

Contact: Chad Swain Swain Phone: 807-830-8198 870-456-0414

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
October, 2022	DO		2.18 mg/l	5.0 mg/l Inst. Min. limit
October, 2022	NH3	19.898 lb/d	32.6 mg/l	11.5 lb/d Avg /7.5 mg/l 7 Day Avg limit
October, 2022	Fc		>2420 MPN/100ml	2000 MPN/100ml 7day Geo limit

We feel this problem was due to:

We had a blower unit go out, which depletes the oxygen. We got 1.5 of rainfall on 11-5-22 & 11-15-22 we got 0.5 of rainfall

We plan on correcting the problem in this manner:

We have replaced blower motor & recirculating the water every day to help this issue

Time estimated that it will take to correct the problem/s:

1 month

Sincerely,

Maan Maan

Authorized Signature

11-22-22

Date