

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411

Discharge Number: 001-A-Monthly

Facility: Hazen

Address: 1789 Utility Street

City: Hazen

State: AR

Zip: 72064

Contact: Chad Swaim

Phone: 8708308198

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
October-23	D.O.		3.30mg/L Inst. Min	5.0mg/L Inst. Min

We feel this problem was due to:

We had an aerator malfunction

We plan on correcting the problem in this manner:

Replacing the aerator

Time estimated that it will take to correct the problem/s:

1 Week

Sincerely,

~~\_\_\_\_\_~~ Mason Martin

Authorized Signature

11-17-23

Date